

School Name	Room Number	Sample ID <small>(School # - room # - sink #)</small>	Results		Flushing Requirement
			Standing	Flushed	
Adult H.S.	Filling Station	227-F56-A	0.006	0.007	daily
		227-F56-B	0.006	0.028 resample 1 = 0.017 resample 2 = 0.001 resample 3 = 0.001	daily
	Filling Station	227-F57-A	0.003	0.001	daily
		227-F57-B	0.003	0.001	daily
	Filling Station	227-F58-A	<0.001	<0.001	daily
Albert Street Admin.	Filling Station	227-F58-B	0.001	<0.001	daily
	Filling Station	364-F51-B	<0.001	<0.001	daily
A.Y. Jackson	Filling Station	201-F53-A	0.004	0.001	weekly
	Filling Station	201-F54-A	0.015	0.010	daily
	Filling Station	201-F56-A	0.002	<0.001	no flushing
	Filling Station	201-F56-B	0.002	<0.001	no flushing
Bell High School	Filling Station	201-F57-A	<0.001	<0.001	no flushing
	Filling Station	201-F57-B	<0.001	0.002	no flushing
Brookfield HS	Filling Station	202-F511-B	0.004	0.001	daily
	Filling Station	228-F55-A	0.007	0.009	daily
Canterbury H.S.	Filling Station	228-F55-B	0.014	0.005	daily
	Filling Station	229-F4-F5-A	0.003	0.002	daily
Cairine Wilson	Filling Station	229-F4-F5-B	0.007	0.003	daily
	Filling Station	203-F53-A	0.001	<0.001	daily
	Filling Station	203-F53-B	0.002	<0.001	daily
	Filling Station	203-F54-A	0.002	<0.001	weekly
	Filling Station	203-F55-A	0.002	0.001	daily
	Filling Station	203-F55-B	0.004	0.003	daily
Colonel By S.S.	Filling Station	203-F56-A	0.001	<0.001	weekly
	Filling Station	203-F56-B	0.002	<0.001	weekly
Confederation	Filling Station	204-F56-A	0.002	0.002	daily
	Filling Station	204-F56-B	0.002	0.002	daily
Earl of March H.S.	Filling Station	205-F51-B	0.012	0.003	daily
Frederick Banting	101E - main office kitchenette	206-101E-1	<0.001	<0.001	daily
Glebe Collegiate	139 - kitchen - off gym	221-Kitchen-1	0.039	0.008	daily
	Filling Station	230-F55-A	0.008	0.003	daily
		230-F55-B	0.014	0.004	daily
	Filling Station	230-F56-A	0.002	<0.001	daily
		230-F56-B	0.004	0.001	daily
	Filling Station	230-F57-A	0.001	<0.001	daily
		230-F57-B	<0.001	0.003	daily
		230-F58-A	0.019	0.010	daily
	Filling Station	230-F58-B	0.063	0.011 resample 1 = 0.006 resample 2 = 0.004	daily
		230-F59-A	0.004	0.002	daily
Gloucester H.S.	1128B - kitchen	208-14-1	0.002	0.001	daily
Hillcrest H.S.	Filling Station	231-F515-B	0.051	0.008	daily
John McCrae S.S.	Filling Station	238-F51-B	<0.001	<0.001	no flushing
Lisgar Collegiate	Filling Station	226-F53-B	0.003	0.002	daily
Longfields-Davidson Heights S.S.	Filling Station	239-F51-B	<0.001	<0.001	no flushing
Merivale High School	Filling Station	210-F57-A	0.006	0.002	daily
		210-F57-B	0.006	0.003	daily
	Filling Station	210-F58-B	0.038	0.008	daily
		210-F59-B	0.005	0.002	daily
	Filling Station	210-F510-B	0.005	0.001	daily
		210-F511-B	0.003	0.001	daily
Nepean H.S.	Filling Station	234-F54-A	0.002	0.003	daily
		234-F54-B	0.007	0.006	daily
	Filling Station	234-F55-B	0.010	0.009	daily
		234-F56-B	0.061	0.004	daily
	Filling Station	234-F57-B	0.015	0.010	daily
	234-F58-B	<0.001	<0.001	daily	
Norman Johnston	Filling Station	220-F51-B	0.009	0.003	daily
Osgoode Township H.S.	Filling Station	212-F51-B	0.003	0.001	weekly
Ottawa Tech.	Filling Station	233-F51-B	0.003	0.001	daily
Ridgemont H.S.	Filling Station	236-F53-A	<0.001	<0.001	daily
		236-F53-B	0.001	<0.001	daily
	Filling Station	236-F54-A	0.009	0.003	daily
		236-F54-B	0.012	0.005	daily
Sir Guy Carleton	Filling Station	211-F53-A	0.005	<0.001	daily
		211-F55-A	0.002	<0.001	daily
	Filling Station	211-F55-B	0.002	0.001	daily
		211-F57-A	<0.001	<0.001	daily
	211-F57-B	<0.001	<0.001	daily	
Sir Robert Borden H.S.	Filling Station	213-F58-A	<0.001	<0.001	daily
		213-F58-B	<0.001	<0.001	daily
Sir Wilfred Laurier S.S.	Filling Station	218-F54-A	<0.001	<0.001	no flushing
		218-F54-B	0.001	<0.001	no flushing
	Filling Station	218-F55-A	0.004	0.002	weekly
		218-F55-B	0.010	0.001	weekly
	Filling Station	218-F56-A	0.002	0.001	weekly
		218-F56-B	0.001	0.002	weekly
	Filling Station	218-F57-A	0.002	0.002	weekly
		218-F57-B	0.001	0.002	weekly
	Filling Station	218-F58-A	0.003	0.002	weekly
		218-F58-B	0.003	0.003	weekly
	218-F59-A	<0.001	<0.001	no flushing	
	218-F59-B	<0.001	<0.001	no flushing	
South Carleton H.S.	Filling Station	214-F55-A	<0.001	<0.001	daily
		214-F55-B	<0.001	<0.001	daily
	Filling Station	214-F56-A	0.001	<0.001	daily
		214-F56-B	0.001	<0.001	daily
	Filling Station	214-F57-A	<0.001	<0.001	daily
	214-F57-B	<0.001	0.001	daily	
West Carleton SS	150 - staff lounge	219-150-1	0.011	0.006	daily
Woodroffe H.S.	107-Guidance Kitchen	237-guidance kitchen-1	0.011	0.003	daily

Safe Drinking water Act 2002, Ontario Regulation 243/07 Indicates the maximum allowable concentration of lead in drinking water is 0.010mg/L, (milligrams/litre)

Red indicates an exceedance in the lead concentration above 0.010mg/L in a flushed sample. The resample results shown are after corrective actions were taken.

Orange indicates an exceedance in the lead concentration above 0.010mg/L in a standing sample.