

School Name	Room Number	Sample ID (school # - room # - sink #)	Results		Flushing Requirement
			Standing	Flushed	
<b>A. Lorne Cassidy</b>	103-staffroom	071-Staffroom-1	<0.001	<0.001	daily
<b>Adrienne Clarkson</b>	134b-servery	051-127B-2	0.008	<0.001	daily
<b>Barrhaven</b>	Filling Station	001-FS1-B	0.003	0.001	daily
<b>Berrigan</b>	Filling Station	137-FS1-B	<0.001	<0.001	no flushing
<b>Castor Valley</b>	Filling Station	063-FS1-B	<0.001	<0.001	no flushing
<b>Cedarview</b>	Filling Station	073-FS1-B	<0.001	<0.001	no flushing
<b>Chapman Mills</b>	Filling Station	147-FS5-A	<0.001	<0.001	no flushing
		147-FS5-B	<0.001	<0.001	no flushing
<b>D.A. Moodie</b>	Filling Station	012-FS1-A	0.010	0.002	daily
		012-FS1-B	0.043	0.025	daily
				resample 1 = 0.019	
				resample 2 = 0.014	
	Filling Station	012-FS2-A	0.002	<0.001	daily
		012-FS2-B	0.001	<0.001	daily
	Drinking Fountain	012-F1	0.001	0.002	daily
	Drinking Fountain	012-F2	0.001	<0.001	daily
	Drinking Fountain	012-F3	0.016	0.012	daily
				resample 1 = 0.005	
	Staffroom	012-Lib/Staff-1	0.062	0.081	daily
				resample 1 = 0.009	
EDP Kitchen	012-kit-1	0.387	0.017	daily	
			resample 1 = 0.023		
			resample 2 = 0.005		
<b>Farley Mowat</b>	Filling Station	142-FS1-B	<0.001	<0.001	no flushing
		020-FS3-A	0.004	0.002	daily
<b>Goulbourn</b>	Filling Station	020-FS3-B	0.005	0.002	daily
		111-kindergarten	022-111-2	0.001	<0.001
<b>Greely</b>					
<b>Half Moon Bay</b>	Filling Station	153-FS1-B	<0.001	<0.001	no flushing
<b>Jockvale</b>	102 - staffroom	061-Staff-1	0.004	0.001	daily
<b>Kars on the Rideau</b>	Filling Station	047-FS5-A	<0.001	<0.001	no flushing
		047-FS5-B	<0.001	<0.001	no flushing
<b>Manotick</b>	111	035-10-2	0.016	0.001	daily
<b>Mary Honeywell</b>	Filling Station	069-FS1-B	<0.001	<0.001	no flushing
<b>Metcalfe</b>	Filling Station	039-FS1-B	0.001	<0.001	weekly
<b>North Gower</b>	116 - teachers room	041-114-1	0.003	<0.001	weekly
<b>Osgoode P.S.</b>	Filling Station	042-FS2-B	<0.001	<0.001	no flushing
<b>Richmond</b>	117 - kindergarten	046-117-1	<0.001	<0.001	daily
<b>Stittsville P.S.</b>	103-kindergarten	140-103-2	0.017	0.001	daily
<b>Westwind</b>	Filling Station	150-FS5-A	<0.001	<0.001	no flushing
		150-FS5-B	<0.001	<0.001	no flushing

Safe Drinking water Act 2002, Ontario Regulation 243/07 Indicates the maximum allowable concentration of lead in drinking water is 0.010mg/L (milligrams/litre)

Red indicates an exceedance in the lead concentration above 0.010mg/L in a flushed sample. The resample results shown are after corrective actions were taken.

Orange indicates an exceedance in the lead concentration above 0.010mg/L in a standing sample.