

School Name	Room Number	Sample ID (school # - room # - sink #)	Results		Flushing Requirement
			Standing	Flushed	
Agincourt	Staff Room-103	076-103-1	0.011	0.002	daily
Briargreen	135	006-135-1	0.010	0.002	daily
Broadview	Filling Station	080-FS1-B	<0.001	<0.001	no flushing
Churchill	Filling Station	086-FS1-B	<0.001	<0.001	no flushing
D.Roy Kennedy	Filling Station	090-FS3-A	<0.001	<0.001	daily
		090-FS3-B	0.002	<0.001	daily
	Filling Station	090-FS4-A	0.006	0.001	daily
		090-FS4-B	0.011	0.001	daily
Elizabeth Wynwood	Filling Station	216-FS1-B	<0.001	<0.001	no flushing
Knoxdale	Filling Station	029-FS2-B	0.002	0.001	daily
Greenbank	Filling Station	023-FS3-A	0.022	0.005	daily
		023-FS3-B	0.024	0.004	daily
Manordale	101 - staffroom	034-2-1	<0.001	<0.001	no flushing
Meadowlands	Filling Station	036-FS1-B	<0.001	<0.001	weekly
Pinecrest	Filling Station	115-FS1-B	<0.001	<0.001	daily
Regina Street	Filling Station	123-FS1-B	<0.001	<0.001	daily
Severn Ave	Filling Station	128-FS1-B	<0.001	<0.001	no flushing
Sir Winston Churchill	100C - nurses room	052-100C-1	0.009	0.003	weekly
Woodroffe Avenue P.S	Filling Station	133-FS3-B	0.003	0.005	daily

Safe Drinking water Act 2002, Ontario Regulation 243/07 Indicates the maximum allowable concentration of lead in drinking water is 0.010mg/L (milligrams/litre)

Red indicates an exceedance in the lead concentration above 0.010mg/L in a flushed sample. The resample results shown are after corrective actions were taken.

Orange indicates an exceedance in the lead concentration above 0.010mg/L in a standing sample.