

School Name	Room Number	Sample ID (school # - room # - sink #)	Results		Flushing Requirement
			Standing	Flushed	
Alta Vista	120 - staffroom	077-120-3	0.029	0.015	daily
				resample 1 = 0.013	
				resample 2 = 0.006	
				resample 3 = 0.109	
				resample 4 = 0.007	
resample 5 = 0.001					
Arch Street	109B kitchen	078-109B-1	0.073	0.014	daily
				resample 1 = 0.007	
				resample 2 = 0.013	
				resample 3 = 0.004	
resample 4 = 0.002					
Bayview	106-kindergarten	121-106-2	0.051	0.043	daily
				resample 1 = 0.014	
				resample 2 = 0.516	
				resample 3/4 = 0.491	
				resample 5 = 0.020	
				resample 6 = 0.007	
				resample 7 = 0.003	
Blossom Park	Filling Station	005-FS3-A	<0.001	<0.001	daily
		005-FS3-B	<0.001	<0.001	daily
	Filling Station	005-FS4-A	0.002	<0.001	daily
		005-FS4-B	0.003	<0.001	daily
Carleton Heights	Filling Station	082-FS1-B	0.002	<0.001	daily
Charles Hulse	Filling Station	084-FS3-A	<0.001	<0.001	daily
		084-FS3-B	<0.001	<0.001	daily
	Filling Station	084-FS4-A	0.013	0.003	daily
		084-FS4-B	0.006	0.003	daily
Clifford Bowey	Bottle filler	087-FS1-B	0.001	<0.001	daily
Dunlop	Filling Station	092-FS2-A	0.005	0.002	daily
		092-FS2-B	0.012	0.002	daily
	Filling Station	092-FS3-A	0.009	0.002	daily
		092-FS3-B	0.013	0.003	daily
Featherston Drive	Filling Station	095-FS7-A	0.007	0.002	daily
		095-FS7-B	0.013	0.006	daily
Fielding Drive	Filling Station	096-FS4-B	0.001	0.001	daily
General Vanier	Filling Station	099-FS1-B	<0.001	<0.001	no flushing
Hawthorne	140A kitchen off gym	104-140A-1	0.013	0.004	daily
Pleasant Park	121-b Kitchen	116-121B-2	0.002	<0.001	daily
Riverview	Filling Station	124-FS3-A	<0.001	<0.001	daily
		124-FS3-B	<0.001	<0.001	daily
	Filling Station	124-FS4-A	<0.001	<0.001	daily
		124-FS4-B	<0.001	<0.001	daily
Robert Bateman	150 - Gym Kitchen	125-Kitchen-1	<0.001	<0.001	no flushing
Roberta Bondar	Filling Station	126-FS4-A	<0.001	<0.001	no flushing
		126-FS4-B	<0.001	<0.001	no flushing
	Filling Station	126-FS5-A	<0.001	<0.001	no flushing
		126-FS5-B	<0.001	<0.001	no flushing
Sawmill Creek	Filling Station	075-FS1-B	<0.001	<0.001	daily
	Filling Station	075-FS4-B	<0.001	<0.001	daily
Steve MacLean	Filling Station	141-FS4-A	<0.001	<0.001	no flushing
		141-FS4-B	<0.001	<0.001	no flushing
Vimy Ridge	Filling Station	148-FS1-B	<0.001	<0.001	no flushing
Vincent Massey	Filling Station	129-FS1-B	0.002	<0.001	daily

Safe Drinking water Act 2002, Ontario Regulation 243/07 Indicates the maximum allowable concentration of lead in drinking water is 0.010mg/L (milligrams/litre)

Red indicates an exceedance in the lead concentration above 0.010mg/L in a flushed sample. The resample results shown are after corrective actions were taken.

Orange indicates an exceedance in the lead concentration above 0.010mg/L in a standing sample.