

School Name	Room Number	Sample ID <small>(school # - room # - sink #)</small>	Results		Flushing Requirement
			Standing	Flushed	
Cambridge Street	Filling Station	081-FS2-B	0.049	0.012	daily
				resample 1 = 0.008	
				resample 2 = 0.008	
Centennial	137-kindergarten	083-17-1	0.027	0.010	daily
Connaught	115 servery	088-133-1	<0.001	<0.001	daily
Devonshire	209A-kindergarten	091-209A-1	<0.001	0.002	weekly
Elgin Street	113-kindergarten	093-113-1	0.020	0.003	daily
Elmdale	Filling Station	094-FS1-B	<0.001	<0.001	no flushing
First Avenue	Filling Station	097-FS1-B	0.003	0.001	daily
Fisher Park	Filling Station	098-FS5-A	0.003	0.001	daily
		098-FS5-B	<0.001	<0.001	daily
	Filling Station	098-FS6-A	0.005	<0.001	daily
		098-FS6-B	0.008	<0.001	daily
	Filling Station	098-FS7-A	0.006	0.002	daily
		098-FS7-B	1.002	0.006	daily
	Filling Station	098-FS8-A	0.001	<0.001	daily
098-FS8-B		0.004	<0.001	daily	
Glashan	Filling Station	102-FS4-A	0.009	0.002	daily
		102-FS4-B	0.013	0.003	daily
Hilson Avenue	room 101	105-107-1	<0.001	<0.001	daily
Hopewell Avenue	Filling Station	106-FS2-A	<0.001	<0.001	no flushing
		106-FS2-B	<0.001	<0.001	no flushing
	Filling Station	106-FS3-A	<0.001	<0.001	no flushing
		106-FS3-B	<0.001	<0.001	no flushing
	Filling Station	106-FS4-A	<0.001	<0.001	no flushing
106-FS4-B	<0.001	<0.001	no flushing		
Lady Evelyn	Filling Station	135-FS2-A	<0.001	<0.001	daily
		135-FS2-B	<0.001	<0.001	daily
	Filling Station	135-FS3-A	<0.001	<0.001	daily
		135-FS3-B	<0.001	<0.001	daily
Manor Park	Filling Station	110-FS1-B	0.001	<0.001	daily
Mutchmor	Filling Station	113-FS6-A	0.009	<0.001	daily
		113-FS6-B	0.005	0.005	daily
Queen Elizabeth	Filling Station	118-FS4-A	0.012	0.002	daily
		118-FS4-B	0.051	0.008	daily
	Filling Station	118-FS5-A	<0.001	<0.001	daily
		118-FS5-B	<0.001	<0.001	daily
	Filling Station	118-FS6-A	0.001	<0.001	daily
		118-FS6-B	0.007	<0.001	daily
Queen Mary	Filling Station	119-FS2-A	0.008	0.004	daily
		119-FS2-B	0.019	0.015	daily
	Filling Station	119-FS3-A	0.007	0.004	daily
		119-FS3-B	0.018	0.004	daily
Richard Pfaff	Filling Station	112-FS2-A	0.003	<0.001	daily
	Bottle filler	112-FS3-B	0.001	0.006	daily
Robert E Wilson	103-staffroom	122-103-1	0.009	0.006	daily
Rockcliffe Park	Filling Station	127-FS3-A	0.005	0.002	daily
		127-FS3-B	0.005	0.002	daily
	Filling Station	127-FS4-A	0.006	0.002	daily
		127-FS4-B	0.006	0.002	daily
Viscount Alexander	Filling Station	130-FS2-A	0.004	0.001	daily
		130-FS2-B	0.004	0.001	daily
	Filling Station	130-FS3-A	0.066	0.022	daily
W.E Gowling	Filling Station	134-FS3-A	<0.001	<0.001	no flushing
		134-FS3-B	<0.001	<0.001	no flushing
York Street	Filling Station	134-FS4-A	<0.001	<0.001	no flushing
		134-FS4-B	<0.001	<0.001	no flushing
	Filling Station	134-FS5-A	<0.001	<0.001	no flushing
		134-FS5-B	0.001	<0.001	no flushing

Safe Drinking water Act 2002, Ontario Regulation 243/07 Indicates the maximum allowable concentration of lead in drinking water is 0.010mg/L (milligrams/litre)

Red indicates an exceedance in the lead concentration above 0.010mg/L in a flushed sample. The resample results shown are after corrective actions were taken.

Orange indicates an exceedance in the lead concentration above 0.010mg/L in a standing sample.