

School Name	Room Number	Sample ID (school # - room # - sink #)	Results		Flushing Requirement	
			Standing	Flushed		
Avalon	114 kitchen-off gym	143-114-2	0.034	0.006	daily	
Carson Grove	Filling Station	008-FS4-A	<0.001	<0.001	daily	
		008-FS4-B	<0.001	<0.001	daily	
Convent Glen	Filling Station	011-FS2-A	0.004	0.001	daily	
		011-FS2-B	0.007	0.002	daily	
Dunning-Foubert	Bottle Filler	058-FS3-B	0.004	0.002	daily	
	Bottle Filler	058-FS4-B	0.003	0.001	daily	
Emily Carr	Filling Station	013-FS1-B	0.002	0.002	weekly	
Fallingbrook	101 - staff lounge	065-123-1	0.013	0.003	daily	
Forest Valley	102 - Staff Room kitchen	067-Staff-1	<0.001	<0.001	daily	
Glen Ogilvie	216 - Staff Room	019-Staff-1	0.005	0.004	daily	
Henry Larsen	Filling Station	062-FS4-A	0.012	0.001	daily	
		062-FS4-B	0.006	0.002	daily	
	Filling Station	062-FS5-A	0.004	0.002	daily	
		062-FS5-B	0.016	0.003	daily	
Henry Munro	Filling Station	025-FS3-A	0.007	<0.001	daily	
		025-FS3-B	0.003	<0.001	daily	
	Filling Station	025-FS4-A	0.008	0.001	daily	
		025-FS4-B	0.099	0.002	daily	
Heritage	Filling Station	138-FS2-A	<0.001	<0.001	no flushing	
		138-FS2-B	<0.001	<0.001	no flushing	
	Filling Station	138-FS3-A	<0.001	<0.001	no flushing	
		138-FS3-B	<0.001	<0.001	no flushing	
	Filling Station	138-FS4-A	<0.001	<0.001	no flushing	
		138-FS4-B	<0.001	<0.001	no flushing	
Le Phare	Filling Station	032-FS1-B	<0.001	<0.001	no flushing	
MacSkimming Farm	Pioneer Village	Mac-Pioneerkitchen-1	<0.001	<0.001	weekly	
	Pioneer/Galloway	Mac-Galloway -1	0.005	<0.001	weekly	
	Trails End	Mac-Trails-2	0.002	<0.001	weekly	
	Agriculture	Mac-Agriculture-1	0.001	<0.001	weekly	
Maple Ridge	Filling Station	060-FS1-B	<0.001	<0.001	no flushing	
Orleans Wood	Filling Station	059-FS2-A	0.003	<0.001	daily	
		059-FS2-B	0.005	<0.001	daily	
		059-FS3-A	0.023	0.004	daily	
	Filling Station	059-FS3-B	0.036	0.012	resample 1 = 0.010 resample 2 = 0.003	daily
	Filling Station	059-FS4-A	0.001	<0.001	daily	
059-FS4-B		0.002	<0.001	daily		
Robert Hopkins	Filling Station	049-FS2-A	0.002	<0.001	daily	
		049-FS2-B	0.003	<0.001	daily	
	Filling Station	049-FS3-A	0.040	0.005	daily	
		049-FS3-B	0.048	0.007	daily	
SummerSide	103 - staffroom	151-103-1	<0.001	0.001	no flushing	
Terry Fox	133 - Servery - off gym	024-Servery-1	0.015	0.005	daily	
Trillium	120a - Kitchen - off gym	072-Kitchen-1	0.002	<0.001	weekly	

Safe Drinking water Act 2002, Ontario Regulation 243/07 Indicates the maximum allowable concentration of lead in drinking water is 0.010mg/L (milligrams/litre)

Red indicates an exceedance in the lead concentration above 0.010mg/L in a flushed sample. The resample results shown are after corrective actions were taken.

Orange indicates an exceedance in the lead concentration above 0.010mg/L in a standing sample.