

School Name	Room Number	Sample ID (school # - room # - sink #)	Results		Flushing Requirement
			Standing	Flushed	
Adult H.S.	243	227-202-1	0.003	0.001	daily
	Filling Station	227-FS9-A	0.001	<0.001	daily
		227-FS9-B	0.002	0.001	daily
		227-FS10-A	0.005	0.001	daily
	Filling Station	227-FS10-B	0.008	0.008	daily
Albert Street Admin.	Filling Station	364-FS4-B	0.002	0.007	daily
Cambridge Street	mudroom 116-117	081-4/5-1	0.020	0.008	daily
Centennial	Filling Station	083-FS6-A	0.017	0.003	daily
		083-FS6-B	0.013	0.005	daily
Connaught	Filling Station	088-FS4-A	0.002	0.001	daily
		088-FS4-B	0.003	<0.001	daily
Devonshire	B112A kitchen	091-B112A-1	<0.001	<0.001	weekly
Elgin Street	107-kindergarten	093-107-1	0.023	0.001	daily
Elmdale	Filling Station	094-FS2-B	<0.001	<0.001	no flushing
First Avenue	117-kindergarten	097-101-2	0.011	0.004	daily
Fisher Park	235 - Staff Lounge	098- Staff-1	0.567	0.019 resample 1 = 0.019 resample 2 = 0.008 resample 3 = 0.014 resample 4 = 0.069 resample 5 = 0.008 resample 6 = 0.008	daily
Glashan	Filling Station	102-FS1-B	0.003	0.001	daily
Glebe Collegiate	Filling Station	230-FS1-B	0.002	0.001	daily
Hilson Avenue	Filling Station	105-FS3-B	0.017	0.006	daily
Hopewell Avenue	219 kitchen-off gym	106-212-2	0.001	<0.001	weekly
Lady Evelyn	310	135-310-1	<0.001	<0.001	daily
Lisgar Collegiate	Filling Station	226-FS4-B	0.004	0.008	daily
Manor Park	105D - Gym Kitchen	110-Kitchen-1	0.333	0.024 resample 1 = 0.038 resample 2 = 0.043 resample 3 = 0.032 resample 4 = 0.005 resample 5 = 0.004	daily
Mutchmor	123-kindergarten	113-123-2	0.006	0.002	daily
Queen Elizabeth	129	118-15-1	<0.001	<0.001	daily
Queen Mary	210 - temp. staffroom	119-210-1	0.004	0.001	
Richard Pfaff	Filling Station	112-FS1-B	0.005	0.002	daily
Robert E Wilson	124-kindergarten	122-124-1	0.233	0.055 resample 1 = 0.016 resample 2 = 0.015 resample 3 = 0.002	daily
Rockcliffe Park	116 - kindergarten	127-24-1	<0.001	<0.001	daily
Viscount Alexander	125-kindergarten	130-10-1	0.001	0.001	daily
W.E. Gowling	151-kindergarten	131-151-1	0.007	0.030 resample 1 = 0.005 resample 2 = 0.011 resample 3 = 0.004 resample 4 = 0.004	daily
York Street	105-kindergarten	134-113-1	0.014	0.014 resample 1 = 0.002 resample 2 = 0.002	daily

Safe Drinking water Act 2002, Ontario Regulation 243/07 Indicates the maximum allowable concentration of lead in drinking water is 0.010mg/L (milligrams/litre)

Red indicates an exceedance in the lead concentration above 0.010mg/L in a flushed sample.

Orange indicates an exceedance in the lead concentration above 0.010mg/L in a standing sample.